



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

Diary No. 790

Dated: 5/03/25



No. F6/DFS/MS/2025/School/198

Dated: 28/02/2025

FIRE SAFETY CERTIFICATE

Certified that the Sant Nirankari Girls Sr. Sec. School located at Sant Nirankari Colony, Delhi-110009 comprised of 04 New blocks interconnected (Ground & 03 upper floors each) owned/ occupied by Sant Nirankari Girls Sr. Sec. School was issued Fire Safety Certificated vide this office letter no. F6/DFS/MS/School/2022/WZ/560 dated 20.05.2022. The premise was inspected by the officer concerned of this department on 03.01.2025 in the presence of Smt. Rishika (Sr. Accountant) and observed that all the fire prevention and fire safety arrangements as provided in the premise found in good working condition The premise have therefore deemed complied with the requirements under rule 33 of the Delhi Fire Service Rules, 2010 and the building premise is fit for occupancy class "Educational Group B (School)" with effect from 28/02/2025 for a period of three years, in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under rule 40, subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010,

Issued on 28/02/2025 at New Delhi

(Atul Barg)
Director
Ph: 011-23414000

Copy to: -

1. The Dy. Director of Education, Zone-IX, DNW-A, Shalimar Bagh, BL Block, Delhi-110088.
2. The Principal, Sant Nirankari Girls Sr. Sec. School located at Sant Nirankari Colony, Delhi-110009.

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape shall be kept free from any type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipment and method of smooth and speedy safe evacuation of occupants in case of emergency
3. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seem during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities. This Fire Safety Certificate is valid only for permanent building structure as per plan.
5. This fire safety certificate may not be treated in any case of regularizations of unauthorized construction/unauthorized use of land or activities, if any.
6. The owner / occupier shall submit a declaration every year in Form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on the official website of Delhi Fire Service i.e. www.dfs.delhigovt.nic.in.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".